

NS RIF:

SURVEY REPORT

VESSEL:

Survey

Date of Survey

Place of Survey

FAC SIMILE

	NAME	CERT No. / LEVEL	RULE:
<i>Operator :</i>			UNI EN ISO 18436-2
	NAME	SIGNATURE	DATE
<i>Prepared by :</i>			

INDEX

INTRODUCTION	Page	3
THE SURVEY		3
REPORT		4
<u>Used instruments</u>		4
ANALYSIS RESULTS		6
<u>Rating Criteria</u>		7
VIBRATION ANALYSIS		
THERMOGRAPHIC CONTROL		
POWER QUALITY TEST CONTROL		

INTRODUCTION

Date and Place of Survey

The survey was conducted on board the vessel from 2nd level
analyst's with assistance being given by Engineer officers on
board.

THE SURVEY

Purpose

The purpose of the survey is to check:

- Machinery apparatus and electric system by vibration analysis method, with thermographic control and power quality control.

Reporting

For the machines object of this analysis, the following criteria was applied:

Vibration analysis:

- ISO 10816-3, ISO 10816-6, ISO 10816-7 & ISO 8528-9;

Thermographic control:

- ISO 7726;

Power quality control:

- EN 50160;

REPORT:

Used instruments

Spectrum analyzer and vibrometer model **FLUKE** with the following technical features:

- Frequency range: 20 – 2000 Hz;
- Measuring system: (mm/sec – RMS);
- Number of averages: 5;
- Number of lines: 800;
- Serial number: 3094008.

Sensor Type: accelerator model **FLUKE 3530769** with magnetic base:

- Sensitivity: 100 mV/g ($\pm 5\%$, 25 °C);
- Frequency range: Z Da 2 a 7.000 Hz ± 3 dB;
X, Y Da 2 a 5.000 Hz ± 3 dB;
- Serial number: 6252.

Vibrometer model **Lutron** with the following technical features:

- Frequency range: 10 – 1000 Hz;
- Measuring system: (mm/sec – RMS);
- Number of averages: 4;
- Number of lines: 400;
- Serial number: Q812199.

Infrared Camera FLIR T660:

- Thermal Resolution: 307,200 (640 × 480);
- Thermal Sensitivity : <0.02°C @ 30°C;
- Accuracy: +/-1°C (+/-1.8°F) or +/-1% of reading for limited temperature range;
±2°C (±3.6°F) or 2%, whichever is greater, at 25°C (77°F) nominal;
- Temperature Range: -40°F to 3,632°F (-40°C to 2,000°C);
- Serial number: **55906789**.

Power quality tester by FLUKE 435 II

Ultrasonic Tester SDT 270

ANALYSIS RESULTS

COMPONENT	VIBRATION ANALYSIS RESULT	THERMOGRAPHIC INSPECTION RESULT	TOTAL RUNNING HOURS	POWER QUALITY RESULT
AUX GENERATOR No.1	ISO 10816-6 LEVEL A/B	NO FAULTS DETECTED		TEST PASSED
AUX GENERATOR No.2	ISO 10816-6 LEVEL B	NO FAULTS DETECTED		TEST PASSED
AUX GENERATOR No.3	ISO 10816-6 LEVEL A/B	NO FAULTS DETECTED		TEST PASSED
EMERGENCY GENERATOR	ISO 8528-9 LEVEL A	NO FAULTS DETECTED		
MAIN ENGINE	ND	NO FAULTS DETECTED		
M.E. CIRCULATING PUMP No.2	ISO 10816-3	NO FAULTS DETECTED		
ME FO SUPPLY P/P No.1	ISO 10816-3	NO FAULTS DETECTED		
ME FO SUPPLY P/P No.2	ISO 10816-3	NO FAULTS DETECTED		
G.E. MDO FLUSHING P/P No.2	ISO 10816-3	NO FAULTS DETECTED		
STEERING GEAR PUMP No.1	ISO 10816-3	NO FAULTS DETECTED		
STEERING GEAR PUMP No.2	ISO 10816-3	NO FAULTS DETECTED		
MAIN AIR COMPRESSOR No. 1	ISO 10816-3	ND		
MAIN AIR COMPRESSOR No. 2	ISO 10816-3	ND		
WORKING AIR COMPRESSOR	ISO 10816-3	ND		
PROV.COMPRESSOR No.1	ISO 10816-3	NO FAULTS DETECTED		
PROV.COMPRESSOR No.2	ISO 10816-3	ND		
AIR COND. COMPRESSOR No.2	ISO 10816-3	NO FAULTS DETECTED		
AFT HYD. PACK No.1	ISO 10816-3	ND		
AFT HYD. PACK No.2	ISO 10816-3	ND		
FWD HYD. PACK No.1	ISO 10816-3	ND		
FWD HYD. PACK No.2	ISO 10816-3	ND		
HFO PURIFIER No.2	ND	NO FAULTS DETECTED		

COMPONENT	VIBRATION ANALYSIS RESULT	THERMOGRAPHIC INSPECTION RESULT	TOTAL RUNNING HOURS
MAIN LUBE OIL PUMP No.1	ISO 10816-7	NO FAULTS DETECTED	
MAIN LUBE OIL PUMP No.2	ISO 10816-7	NO FAULTS DETECTED	
MAIN SEA COOLING PUMP No.1	ISO 10816-7	NO FAULTS DETECTED	
MAIN SEA COOLING PUMP No.2	ISO 10816-7	NO FAULTS DETECTED	
MAIN SEA COOLING PUMP No.3	ISO 10816-7	NO FAULTS DETECTED	
JACKET WATER PUMP No.1	ISO 10816-7	NO FAULTS DETECTED	
JACKET WATER PUMP No.2	ISO 10816-7	NO FAULTS DETECTED	
CENTRAL C.F.W. PUMP No.1	ISO 10816-7	NO FAULTS DETECTED	
CENTRAL C.F.W. PUMP No.2	ISO 10816-7	ND	
CENTRAL C.F.W. PUMP No.3	ISO 10816-7	NO FAULTS DETECTED	
BALLAST PUMP No.1	ISO 10816-7	NO FAULTS DETECTED	
BALLAST PUMP No.2	ISO 10816-7	NO FAULTS DETECTED	
FIRE & GS PUMP No.1	ISO 10816-7	NO FAULTS DETECTED	
FIRE & BALLAST PUMP No.2	ISO 10816-7	NO FAULTS DETECTED	
EMERGENCY FIRE PUMP	ISO 10816-7	NO FAULTS DETECTED	

Rating Criteria for Vibration Analysis:

ISO 10816-3 & 10816-7 Vibration Severity Standards

- **GOOD:** The vibration of newly commissioned machines normally falls within this zone.
- **SATISFACTORY:** Machines with vibration within this zone are normally considered acceptable for unrestricted longterm operation.
- **UNSATISFACTORY (ALERT):** Machines with vibration within this zone are normally considered unsatisfactory for long-term continuous operation. Generally, the machine may be operated for a limited period in this condition until a suitable opportunity arises for remedial action.
- **UNACCEPTABLE (DANGER):** Vibration values within this zone are normally considered to be of sufficient severity to cause damage to the machine.

GOOD
SATISFACTORY
UNSATISF.(ALERT)
UNACC. (DANGER)

ISO 10816-6 Vibration Severity Standards

- **LEVEL A/B:** Acceptable for long-term continuous operation.
- **LEVEL C:** Unsatisfactory for long-term continuous operation.
- **OVER LEVEL D:** Sufficient severity to cause damage on the machine

LEVEL A/B - SATISFACTORY
LEVEL C - UNSATISFACTORY (ALERT)
LEVEL D - UNACCEPTABLE (DANGER)

ISO 8528-9 Vibration Severity Standards

- **LEVEL I:** Acceptable for long-term continuous operation.
- **LEVEL II:** Unsatisfactory for long-term continuous operation.
- **OVER LEVEL III:** Sufficient severity to cause damage on the machine

LEVEL I - SATISFACTORY
LEVEL II - UNSATISFACTORY (ALERT)
LEVEL III - UNACCEPTABLE (DANGER)

ISO 7726 Thermography Severity Standards

A means of assessing severity of temperature in evaluating the maintenance scheduling is presented in here follow Tab 3. The degree of temperature rise and criticality of the particular equipment or process involved should determine the final decision as to priorities and order of maintenance.

TEMPERATURE RISE ΔT	REMARKS
$1^{\circ}\text{C} \leq \Delta T < 5^{\circ}\text{C}$	No corrective measures required
$5^{\circ}\text{C} \leq \Delta T \leq 10^{\circ}\text{C}$	Corrective measures required during the next scheduled maintenance period
$10^{\circ}\text{C} < \Delta T \leq 20^{\circ}\text{C}$	Corrective measures to be scheduled on a priority basis
$20^{\circ}\text{C} < \Delta T \leq 30^{\circ}\text{C}$	Corrective measures required as soon as possible
Above 30°C	Corrective measures required immediately

RESULTS AS PER:
ISO 10816-6

VESSEL NAME	APPARATUS	AUX ENGINE No.1	POWER kW	600
IMO	MAKER	HIMSEN HUNDAY	RPM	900
CLASS	MODEL	H17/28	RUN. RMS	17353
Id. No.	LOAD	HUNDAY	322 kW	
OWNER	MODEL	HFC7 504-84K	RPM	900




PLACE OF SURVEY	DATE	START TIME	END TIME	MOORED
		08:00	08:30	

ITEMS	READINGS POSITION	POWER (kW)	FOUND. TYPE	Rpm	FREQ. (Hz)	DISPL. μm	V (mm/s) RMS	RESULT
DIESEL ENGINE								
BEARING 1	1	600	RESILIENT	900	15.00	44.52	2.80	LEVEL A/B
BEARING 1	2	600	RESILIENT	900	15.00	77.90	4.90	LEVEL A/B
BEARING 2	1	600	RESILIENT	900	15.00	42.93	2.70	LEVEL A/B
BEARING 2	2	600	RESILIENT	900	15.00	38.16	2.40	LEVEL A/B
BEARING 3	1	600	RESILIENT	900	15.00	41.34	2.60	LEVEL A/B
BEARING 3	2	600	RESILIENT	900	15.00	33.39	2.10	LEVEL A/B
BEARING 4	1	600	RESILIENT	900	15.00	38.16	2.40	LEVEL A/B
BEARING 4	2	600	RESILIENT	900	15.00	44.52	2.80	LEVEL A/B
BEARING 5	1	600	RESILIENT	900	15.00	50.87	3.20	LEVEL A/B
BEARING 5	2	600	RESILIENT	900	15.00	34.98	2.20	LEVEL A/B
BEARING 6	1	600	RESILIENT	900	15.00	36.57	2.30	LEVEL A/B
BEARING 6	2	600	RESILIENT	900	15.00	42.93	2.70	LEVEL A/B
BEARING 7	1	600	RESILIENT	900	15.00	84.26	5.30	LEVEL A/B
BEARING 7	2	600	RESILIENT	900	15.00	38.16	2.40	LEVEL A/B
CYL LINE 1	3	600	RIGID	900	15.00	7.95	0.50	LEVEL A/B
CYL LINE 2	3	600	RIGID	900	15.00	79.49	5.00	LEVEL A/B
CYL LINE 3	3	600	RIGID	900	15.00	11.92	0.75	LEVEL A/B
CYL LINE 4	3	600	RIGID	900	15.00	31.80	2.00	LEVEL A/B
CYL LINE 5	3	600	RIGID	900	15.00	55.64	3.50	LEVEL A/B
CYL LINE 6	3	600	RIGID	900	15.00	15.90	1.00	LEVEL A/B
ALTERNATOR								
POSITION RADIAL -1Y	4	600	RESILIENT	900	15.00	52.46	3.30	LEVEL A/B
POSITION RADIAL -2Y	5	600	RESILIENT	900	15.00	63.59	4.00	LEVEL A/B
POSITION ASSIAL -3X	6	600	RESILIENT	900	15.00	84.26	5.30	LEVEL A/B
POSITION RADIAL -3Y	6	600	RESILIENT	900	15.00	49.28	3.10	LEVEL A/B
POSITION RADIAL -3Z	6	600	RESILIENT	900	15.00	44.52	2.80	LEVEL A/B
POSITION ASSIAL -4X	7	600	RESILIENT	900	15.00	52.46	3.30	LEVEL A/B
POSITION RADIAL -4Y	7	600	RESILIENT	900	15.00	39.75	2.50	LEVEL A/B
POSITION RADIAL -4Z	7	600	RESILIENT	900	15.00	28.62	1.80	LEVEL A/B
TURBOCHARGER								
POSITION RADIAL -1X	1		RIGID			12.72	0.80	LEVEL A/B
POSITION RADIAL -2Y	2		RIGID			11.13	0.70	LEVEL A/B

ENGINE CLASS	5	ALTERNATOR	VIBRATION SEVERITY	DISPLACEMENT	VELOCITY R.M.S.	ACCELERATION
ISO 10816 -6	ISO 8528 -9	ISO 8528 -9	GR.5 D.G. $\Rightarrow$	μm	(mm/s)	(m/s ²)
3005 RPM $\leq$ 1000	720 $\pm$ RPM $\leq$ 1300	720 $\pm$ RPM $\leq$ 1300	GR.5 ALT. $\Rightarrow$	84.26	5.30	8.31
RMS mm/s	RMS mm/s	RMS mm/s		84.26	5.30	8.31
LEVEL A/B	0 < V < 17.8	0 < V < 20	LEVEL A/B	Acceptable for long-term continuous operation.		
LEVEL C	17.8 < V < 28.2	20 < V < 24	LEVEL C	Unsatisfactory for long-term continuous operation.		
LEVEL D	V > 28.2	V > 24	LEVEL D	Sufficient severity to cause damage on the machine		

Vibration Analyst Name & Certificate Number

ENGINE LEVEL	LEVEL A/B	ALTERNATOR	LEVEL A/B
TURBOCHARGER	LEVEL A/B		



RESULTS AS PER:
ISO 10816-3

ISO 10816-3	LARGE MACHINE POWER 300 kW to 50 MW		MEDIUM SIZED MACHINE POWER 15 kW to 300 kW		SMALL SIZED MACHINE POWER LESS 15 kW	
RATING CRITERIA						
RATING	RMS mm/s	SUPPORT	RMS mm/s	SUPPORT	RMS mm/s	SUPPORT
GOOD	$0 < V \leq 2.3$	RIGID	$0 < V \leq 1.4$	RIGID	$0 < V \leq 0.71$	RIGID
SATISFACTORY	$2.3 < V \leq 4.5$	RIGID	$1.4 < V \leq 2.8$	RIGID	$0.71 < V \leq 1.8$	RIGID
UNSATISF.(ALERT)	$4.5 < V \leq 7.1$	RIGID	$2.8 < V \leq 4.5$	RIGID	$1.8 < V \leq 4.5$	RIGID
UNACC. (DANGER)	$V > 7.1$	RIGID	$V > 4.5$	RIGID	$V > 4.5$	RIGID

GOOD	0<V≤3.5	SOFT	0<V≤2.3	SOFT
SATISFACTORY	3.5<V≤7.1	SOFT	2.3<V≤4.5	SOFT
UNSATISF.(ALERT)	7.1<V≤11	SOFT	4.5<V≤7.1	SOFT
UNACC. (DANGER)	V>11	SOFT	V>7.1	SOFT

Vibration analysis performed during normal operating condition	

Page 17 of 496

THERMOGRAPHIC ANALISYS REPORT		Ns.RIF:
		Vs. RIF:
COSTUMER:	PLACE:	DATE:
		SHEET:
OBJECT:		
.....		
INFRARED THERMOGRAPHIC CONTROL ON AUXILIARY GENERATOR No. 2		
.....		

EQUIPMENT: FLIR T660 - S.N. 55906789	POSITION: ENGINE ROOM	APPARATUS: AUXILIARY GENERATOR No. 2
--	---------------------------------	--

GENERAL INFO ONLY FOR BEARING INSPECTION

Starting time	14:50 LT
Completion time	15:15 LT
NOTE:	Engine stopped on 26/06/2016 at 14:28 LT

INSPECTED PARTS:

ITEM:	COMMENT:
CRANKCASE	Inspected external crankcase and found all in order. No traces of possible overheating, temperature found in the normal range of 85/88 °C
MAIN BEARINGS	All found in order no overheating parts found, average temperature around 85/88 °C see picture details.
CONNECTING ROD BEARINGS	All found in order no overheating parts found, average temperature around 85/88 °C see picture details.
CYLINDER HEAD	After checking all temperatures found in normal operative range.
TURBO CHARGER	All found in order at the time of inspection the air flow was good no any obstruction noted see picture details.
CIRCULATING SYSTEM	Found operative and in order.
ALTERNATOR	All found in order no overheating parts found, average temperature around 42 - 44°C see picture details.
FREE END BEARING	Average temperature around 48 - 50°C see picture details.
DISTRIBUTION PANNEL	All phases found in order and balanced no traces of overheating

RESULTS:

REFERENCE	ITEM	AVERAGE TEMP. °C	OPERATIVE ΔT	CRITICAL T ALARM	RESULT
LINE 1	MAIN BEARING No. 7	85.7	N.A.	100°C	GOOD
LINE 1	MAIN BEARING No. 6	84.7	N.A.	100°C	GOOD
LINE 1	CONNECTING ROD BEARING	84.1	N.A.	100°C	GOOD

REFERENCE	ITEM	AVERAGE TEMP. °C	OPERATIVE ΔT	CRITICAL T ALARM	RESULT
LINE 2	MAIN BEARING No. 6	85.1	N.A.	100°C	GOOD
LINE 2	MAIN BEARING No. 5	84.9	N.A.	100°C	GOOD
LINE 2	CONNECTING ROD BEARING	83.3	N.A.	100°C	GOOD

REFERENCE	ITEM	AVERAGE TEMP. °C	OPERATIVE ΔT	CRITICAL T ALARM	RESULT
LINE 3	MAIN BEARING No. 5	83.8	N.A.	100°C	GOOD
LINE 3	MAIN BEARING No. 4	84.6	N.A.	100°C	GOOD
LINE 3	CONNECTING ROD BEARING	83.6	N.A.	100°C	GOOD

REFERENCE	ITEM	AVERAGE TEMP. °C	OPERATIVE ΔT	CRITICAL T ALARM	RESULT
LINE 4	MAIN BEARING No. 4	85.0	N.A.	100°C	GOOD
LINE 4	MAIN BEARING No. 3	84.2	N.A.	100°C	GOOD
LINE 4	CONNECTING ROD BEARING	84.0	N.A.	100°C	GOOD

REFERENCE	ITEM	AVERAGE TEMP. °C	OPERATIVE ΔT	CRITICAL T ALARM	RESULT
LINE 5	MAIN BEARING No. 3	84.8	N.A.	100°C	GOOD
LINE 5	MAIN BEARING No. 2	85.2	N.A.	100°C	GOOD
LINE 5	CONNECTING ROD BEARING	84.4	N.A.	100°C	GOOD

REFERENCE	ITEM	AVERAGE TEMP. °C	OPERATIVE ΔT	CRITICAL T ALARM	RESULT
LINE 6	MAIN BEARING No. 2	85.2	N.A.	100°C	GOOD
LINE 6	MAIN BEARING No. 1	85.2	N.A.	100°C	GOOD
LINE 6	CONNECTING ROD BEARING	83.0	N.A.	100°C	GOOD

Measurements °C


Sp1 65.1

Parameters

Emissivity 0.64
Refl. temp. 35 °C
Distance 2 m
Atmospheric temp. 24 °C
Ext. optics temp. 20 °C
Ext. optics trans. 1
Relative humidity 50 %

Geolocation

Compass 279° W



Measurements °C

Li1	Max	85.6
	Min	78.2
	Average	83.5
Li2	Max	85.9
	Min	84.4
	Average	85.2

Parameters



Emissivity	0.68
Refl. temp.	35 °C
Distance	2 m
Atmospheric temp.	24 °C
Ext. optics temp.	20 °C
Ext. optics trans.	1
Relative humidity	50 %

Geolocation

Compass	277° W
---------	--------

Note

LINE No.1



Measurements °C

Sp1		81.8
Li1	Max	86.2
	Min	84.0
	Average	85.7
Li2	Max	85.6
	Min	82.4
	Average	84.3

Parameters



Emissivity	0.68
Refl. temp.	35 °C
Distance	2 m
Atmospheric temp.	24 °C
Ext. optics temp.	20 °C
Ext. optics trans.	1
Relative humidity	50 %

Geolocation

Compass	273° W
---------	--------

Note

LINE No.1



Text annotations

Li1	MAIN BEARING No.7
-----	-------------------

Measurements °C


Li1	Max	85.5
	Min	83.0
	Average	84.7

Parameters

Emissivity	0.68
Refl. temp.	35 °C
Distance	2 m
Atmospheric temp.	24 °C
Ext. optics temp.	20 °C
Ext. optics trans.	1
Relative humidity	50 %

Geolocation

Compass	277° W
---------	--------



Text annotations

Li1	MAIN BEARING No.6
-----	-------------------

THERMOGRAPHIC ANALYSIS REPORT		Ns.RIF:
		Vs. RIF:
COSTUMER:	PLACE:	DATE:
		SHEET:
OBJECT:		
INFRARED THERMOGRAPHIC CONTROL ON F.O. SUPPLY PUMP No.2		

EQUIPMENT: FLIR T660 - S.N. 55906789	POSITION: ENGINE ROOM	APPARATUS: F.O. SUPPLY PUMP No.2
---	--------------------------	-------------------------------------

GENERAL INFO:

Starting time	09:04 LT
Completion time	09:06 LT
NOTE:	

INSPECTED PARTS:

ITEM:	COMMENT:
ELECTRIC MOTOR	Distribution of temperature found uniform no evidence of overheating parts.
PUMP	Range of temperature normal, no evidence of leaking.

RESULTS:

All parts inspected found in order.

Measurements °C


Sp1 39.2

Parameters

Emissivity 0.94
Refl. temp. 35 °C
Distance 2 m
Atmospheric temp. 24 °C
Ext. optics temp. 20 °C
Ext. optics trans. 1
Relative humidity 50 %

Geolocation

Compass 303° NW



Measurements °C


Sp1 40.8

Parameters

Emissivity 0.94
Refl. temp. 35 °C
Distance 2 m
Atmospheric temp. 24 °C
Ext. optics temp. 20 °C
Ext. optics trans. 1
Relative humidity 50 %

Geolocation

Compass 290° W



Measurements °C



Sp1 52.4

Parameters

Emissivity 0.94
Refl. temp. 35 °C
Distance 2 m
Atmospheric temp. 24 °C
Ext. optics temp. 20 °C
Ext. optics trans. 1
Relative humidity 50 %

Geolocation

Compass 283° W



Measurements °C



Sp1 55.0

Parameters

Emissivity 0.94
Refl. temp. 35 °C
Distance 2 m
Atmospheric temp. 24 °C
Ext. optics temp. 20 °C
Ext. optics trans. 1
Relative humidity 50 %

Geolocation

Compass 284° W



THERMOGRAPHIC ANALYSIS REPORT		Ns.RIF:
		Vs. RIF:
COSTUMER:	PLACE:	DATE:
		SHEET:
OBJECT:		
.....		
.....		
INFRARED THERMOGRAPHIC CONTROL ON STEERING GEAR PUMP No. 1		
.....		

EQUIPMENT: FLIR T660 - S.N. 55906789	POSITION: ENGINE ROOM	APPARATUS: STEERING GEAR PUMP No. 1
---	--------------------------	--

GENERAL INFO:

Starting time	15:47 LT
Completion time	15:48 LT
NOTE:	

INSPECTED PARTS:

ITEM:	COMMENT:
ELECTRIC MOTOR	Distribution of temperature found uniform no evidence of overheating parts.
PUMP	Range of temperature normal, no problems to be reported.

RESULTS:

All parts inspected found in order.

Measurements °C


Sp1 38.7

Parameters

Emissivity	0.94
Refl. temp.	35 °C
Distance	2 m
Atmospheric temp.	24 °C
Ext. optics temp.	20 °C
Ext. optics trans.	1
Relative humidity	50 %

Geolocation

Compass 287° W



Measurements °C



Sp1 44.7

Parameters

Emissivity	0.94
Refl. temp.	35 °C
Distance	2 m
Atmospheric temp.	24 °C
Ext. optics temp.	20 °C
Ext. optics trans.	1
Relative humidity	50 %

Geolocation

Compass 286° W



Measurements °C



Sp1 39.2

Parameters

Emissivity	0.94
Refl. temp.	35 °C
Distance	2 m
Atmospheric temp.	24 °C
Ext. optics temp.	20 °C
Ext. optics trans.	1
Relative humidity	50 %

Geolocation

Compass 10° N



THERMOGRAPHIC ANALYSIS REPORT		Ns.RIF:
		Vs. RIF:
COSTUMER:	PLACE:	DATE:
		SHEET:
OBJECT:		
INFRARED THERMOGRAPHIC CONTROL ON MAIN COOLING S.W. PUMP No. 1		

EQUIPMENT: FLIR T660 - S.N. 55906789	POSITION: ENGINE ROOM	APPARATUS: MAIN COOLING S.W. PUMP No. 1
---	--------------------------	--

GENERAL INFO:

Starting time	11:35 LT
Completion time	11:36 LT
NOTE:	

INSPECTED PARTS:

ITEM:	COMMENT:
ELECTRIC MOTOR	Distribution of temperature found uniform no evidence of overheating parts.
PUMP	Range of temperature normal, no evidence of leakages.

RESULTS:

All parts inspected found in order.

Measurements °C


Sp1 34.9

Parameters

Emissivity 0.94
Refl. temp. 35 °C
Distance 2 m
Atmospheric temp. 24 °C
Ext. optics temp. 20 °C
Ext. optics trans. 1
Relative humidity 50 %

Geolocation

Compass 80° E



25/06/2016 11:35:22



Measurements °C


Sp1 51.3

Parameters

Emissivity	0.94
Refl. temp.	35 °C
Distance	2 m
Atmospheric temp.	24 °C
Ext. optics temp.	20 °C
Ext. optics trans.	1
Relative humidity	50 %

Geolocation

Compass 271° W



25/06/2016 11:35:13



THERMOGRAPHIC ANALYSIS REPORT		Ns.RIF:
		Vs. RIF:
COSTUMER:	PLACE:	DATE:
		SHEET:
OBJECT:		
INFRARED THERMOGRAPHIC CONTROL ON FIRE & GS PUMP No.1		

EQUIPMENT: FLIR T660 - S.N. 55906789	POSITION: ENGINE ROOM	APPARATUS: FIRE & GS PUMP No.1
---	--------------------------	-----------------------------------

GENERAL INFO:

Starting time	14:14 LT
Completion time	14:16 LT
NOTE:	

INSPECTED PARTS:

ITEM:	COMMENT:
ELECTRIC MOTOR	Distribution of temperature found uniform no evidence of overheating parts
PUMP	Distribution of temperature uniform no leaking detected

RESULTS:

All part inspected found in order.

Measurements °C


Sp1 36.3

Parameters

Emissivity 0.94
Refl. temp. 35 °C
Distance 2 m
Atmospheric temp. 24 °C
Ext. optics temp. 20 °C
Ext. optics trans. 1
Relative humidity 50 %

Geolocation

Compass 278° W



25/06/2016 14:15:01

05/07/2016 12:56:20



FLIR2914-...



FLIR2914.jpg

FLIR T660

55906789


Measurements °C	
Sp1	36.6

Parameters

Emissivity	0.94
Refl. temp.	35 °C
Distance	2 m
Atmospheric temp.	24 °C
Ext. optics temp.	20 °C
Ext. optics trans.	1
Relative humidity	50 %

Geolocation

Compass	203° SW
---------	---------



25/06/2016 14:15:19



Measurements °C

Sp1 35.4

Parameters

Emissivity	0.94
Refl. temp.	35 °C
Distance	2 m
Atmospheric temp.	24 °C
Ext. optics temp.	20 °C
Ext. optics trans.	1
Relative humidity	50 %

Geolocation

Compass 183° S

25/06/2016 14:15:35



FLIR2916.jpg

FLIR T660

55906789

25/06/2016 14:15:35



FLIR2916.jpg

FLIR T660

55906789

05/07/2016 14:34:52



FLIR2916-...

Measurements °C


Sp1 36.8

Parameters

Emissivity	0.94
Refl. temp.	35 °C
Distance	2 m
Atmospheric temp.	24 °C
Ext. optics temp.	20 °C
Ext. optics trans.	1
Relative humidity	50 %

Geolocation

Compass 62° NE



FLIR2917.jpg

FLIR T660

55906789

05/07/2016 13:30:14



FLIR2917-...



FLIR2917.jpg

FLIR T660

55906789

POWER QUALITY CONTROL

Instrument Information

Model Number	FLUKE 430-II
Serial Number	33233112
Firmware Revision	V04.05

Software Information

Power Log Version	5.1
FLUKE 430-II DLL Version	1.1.0.14

General Information

Recording location
Client
Notes

FAC SIMILE

Measurement Summary

Measurement topology	Wye without neutral mode
Application mode	Monitor
First recording	24/06/2016 14:42:34 597msec
Last recording	24/06/2016 18:42:24 597msec
Recording interval	0h 10m 0s 0msec
Nominal Voltage	480 V
Nominal Current	6000 A
Nominal Frequency	60 Hz
File start time	24/06/2016 14:42:24 597msec
File end time	24/06/2016 18:42:24 733msec
Duration	0d 4h 0m 0s 136msec
Number of events	Normal: 36 Detailed: 182
Events downloaded	Yes
Number of screens	10
Screens downloaded	No
Power measurement method	Unified
Cable type	Copper
Harmonic scale	%H1
THD mode	THD 40
CosPhi / DPF mode	Cos Phi



Recording Summary

RMS recordings	24
DC recordings	0
Frequency recordings	1440
Unbalance recordings	24
Harmonic recordings	24
Power harmonic recordings	0
Power recordings	0
Power unbalance recordings	0
Energy recordings	0
Energy losses recordings	0
Flicker recordings	24
Mains signaling recordings	24


Events Summary

Dips	31
Swells	0
Transients	5
Interruptions	0
Voltage profiles	0
Rapid voltage changes	0
Screens	0
Waveforms	0
Intervals without measurements	0
Inrush current graphics	0
Wave events	36
RMS events	36

Mains Signaling. From 24/06/2016 14:42:34 To 24/06/2016 18:42:24



Vrms ph-ph - AB - Average



EN50160 Report

General Information

Recording Location:

Client:

Notes:

Device Information

Instrument: 435-II

Serial: 33233112

User:

Address:

Site:

FW Version: V04.05 2.1

FW Date: 01/09/2015

Measurement Information

Start Date:

End Date:

Duration:

Mode: Monitor

Topology: Wye without neutral mode

Freq: 60Hz

Vnom: 480V

Limits: GR32144

Limit Summary

RMS	>	432.0 V	<	528.0 V	100.0 % of time
THD	<	8 %			100 % of time
Plt	<	1			100.0 % of time
Dip	<	432 V			20 % per week
Swell	>	528 V			20 % per week
Unbal.	<	2 %			95.0 % of time
Hz	>	59.8 Hz	<	60.2 Hz	95.0 % of time

Supply Voltage Variations

L1 RMS Voltage:	100.0 %	Value = 445.50 V
L2 RMS Voltage:	100.0 %	Value = 444.78 V
L3 RMS Voltage:	100.0 %	Value = 444.44 V

Voltage Harmonics

L1	THD:	100 % Value = 1.7 %	PASS
	H2: 95.0 % Value = 1.0%	100 % Value = --.- %	PASS
	H3: 95.0 % Value = 0.5%	100 % Value = --.- %	PASS
	H4: 95.0 % Value = 0.3%	100 % Value = --.- %	PASS

Instrument Information

Model Number	FLUKE 430-II
Serial Number	33233112
Firmware Revision	V04.05

Software Information

Power Log Version	5.1
FLUKE 430-II DLL Version	1.1.0.14

General Information

Recording location
Client
Notes

FAC SIMILE